

Program:	Drinking Water Monitoring Program,Operational Monitoring Program,Project Program	Report Type:	Results Summary Report
AHS:	All	Entered Date Range:	-
PHU:	All	Barcode:	All
Water Utility:	All	Analysis Type:	All
Supply System:	All	Characteristics:	All
Town:	All	Treatment Type:	All
Treatment Plant:	All	Collected Date Range:	01-02-2017 - 28-02-2017
Source:	All		
Sample Site:	All		

Sample Count: 4

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.0600	1.0600	0.0000	1.06	1.06	1	0	1.06	1.06	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	1.0000	1.0400	0.0781	0.91	1.05	3	0	1.05	0.91	100.00
	pH	6.5 - 8.5		7.2667	7.3000	0.0577	7.2	7.3	3	0	7.3	7.2	100.00
	Total Chlorine	5.0000	mg/L	1.2800	1.3100	0.1572	1.11	1.42	3	0	1.42	1.11	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Turbidity	5.0000	NTU	0.3467	0.4000	0.2641	0.06	0.58	3	0	0.58	0.06	100.00